

Transient Stability Analysis with PowerWorld Simulator



T11: Single Machine Infinite Bus Modeling (SMIB)



2001 South First Street
Champaign, Illinois 61820
+1 (217) 384.6330

support@powerworld.com
<http://www.powerworld.com>

Single Machine Infinite Bus (SMIB) Eigenvalue Analysis



- SMIB Eigenvalue Analysis internally builds a dynamic model of one generator connected to an infinite bus
 - All of that generator's dynamic models (machine model, exciter, governor, stabilizer, etc...) are included
 - A matrix (often called the "A Matrix") of all the dynamic states is the constructed at the steady state solution and eigenvalue and eigenvector analysis is performed on this matrix
- These SMIB models can also be saved out as two-bus models consisting of the machine bus and an infinite bus
 - Choose the "Save Two-Bus Equivalent" action
 - These two-bus models can then be further analyzed

SMIB Eigenvalues



- Click Run SMIB Eigen Analysis
 - Positive Eigenvalues = Problem
 - Indicates an unstable dynamic state
 - Negative Eigenvalues with extremely large magnitudes = Problem
 - Indicate a dynamic state that is extremely fast
 - This will cause numerical problems in the integration routines
 - What do these mean?
 - May be a model data error
 - May be a problem with how Simulator is modeling something
- Although this is the last page on the Transient Stability Analysis dialog, it is often one of the first places to look when examining a case

SMIB Eigenvalues



- Extremely large negative eigenvalues are often caused by particular exciter models such as EXST1_GE and REXS which contain extremely fast feedback loops
- These models require special consideration in the numerical integration algorithm and are dealt with by using sub-interval integration

SMIB Eigenvalues Example



- Open the Validation page, click “Run Validation”
- There are many errors and warnings
- Correcting these may help fix some of the large eigenvalues
- Click “Run AutoCorrection”
- Then, view Validation Warnings and Informational Messages to see what was changed

Initial errors and warnings for the case

Element Type	General Type	Model Type	Device Status	Who Am I	Validation Message
1 Generator	Machine Model	GENROU	Active	REEVE_G1_13.8 (10261) #1	Parameter Tdopp must be 4.0 times the time step
2 Generator	Governor	GGOV1	Active	REEVE_G1_13.8 (10261) #1	Parameter Ta must be 4.0 times the time step or zero
3 Generator	Machine Model	GENROU	Active	REEVE_G3_13.8 (10263) #1	Parameter Tdopp must be 4.0 times the time step
4 Generator	Governor	GGOV1	Active	REEVE_G3_13.8 (10263) #1	Parameter Ta must be 4.0 times the time step or zero
5 Generator	Exciter	EXAC3A	Active	SJUAN_G1_22.0 (10318) #1	Parameter Ta must be 4.0 times the time step
6 Generator	Exciter	EXST4B	Active	LEF_G1_18.0 (10394) #1	Parameter Ta must be 4.0 times the time step or zero
7 Generator	Exciter	EXST4B	Active	LEF_G2_18.0 (10395) #1	Parameter Ta must be 4.0 times the time step or zero
8 Generator	Exciter	EXST4B	Active	LEF_S1_18.0 (10396) #1	Parameter Ta must be 4.0 times the time step or zero
9 Generator	Exciter	EXAC2	Active	AFTONS_13.8 (10485) #1	Parameter Tr must be 4.0 times the time step or zero
10 Generator	Exciter	EXAC2	Active	AFTONS_13.8 (10485) #1	Parameter Ta must be 4.0 times the time step
11 Generator	Exciter	EXST4B	Active	AFTONG_18.0 (10486) #1	Parameter Ta must be 4.0 times the time step or zero
12 Generator	Machine Model	GENROU	Active	LDRSBBG1_13.8 (10491) #1	Parameter Tdopp must be 4.0 times the time step
13 Generator	Stabilizer	PSS2A	Active	LDRSBBG1_13.8 (10491) #1	Parameter Tr must be 4.0 times the time step or zero
14 Generator	Machine Model	GENROU	Active	LDRSBRG2_13.8 (10492) #1	Parameter Tdopp must be 4.0 times the time step
15 Generator	Stabilizer	PSS2A	Active	LDRSBRG2_13.8 (10492) #1	Parameter Tr must be 4.0 times the time step or zero
16 Generator	Governor	GGOV1	Active	COPPER_G_13.8 (11051) #1	Parameter Ta must be 4.0 times the time step or zero
17 Generator	Machine Model	GENROU	Active	NEWMANG1_13.8 (11112) #1	Parameter Tdopp must be 4.0 times the time step
18 Generator	Governor	GGOV1	Active	NEWMANG1_13.8 (11112) #1	Parameter Ta must be 4.0 times the time step or zero
19 Generator	Machine Model	GENROU	Active	NEWMANG2_13.8 (11113) #1	Parameter Tdopp must be 4.0 times the time step
20 Generator	Machine Model	GENROU	Active	NEWMANG2_13.8 (11113) #1	Parameter Tdopp must be 4.0 times the time step
21 Generator	Governor	GGOV1	Active	NEWMANG2_13.8 (11113) #1	Parameter Ta must be 4.0 times the time step or zero
22 Generator	Machine Model	GENROU	Active	NEWMANG3_13.8 (11114) #1	Parameter Tdopp must be 4.0 times the time step
23 Generator	Governor	GGOV1	Active	NEWMANG3_13.8 (11114) #1	Parameter Ta must be 4.0 times the time step or zero
24 Generator	Exciter	REXS	Active	NEWMN4G1_13.8 (11115) #1	Parameter Ta must be 4.0 times the time step or zero
25 Generator	Governor	GGOV1	Active	NEWMN4G1_13.8 (11115) #1	Parameter Ta must be 4.0 times the time step or zero
26 Generator	Exciter	REXS	Active	NEWMN4G2_13.8 (11116) #1	Parameter Ta must be 4.0 times the time step or zero
27 Generator	Governor	GGOV1	Active	NEWMN4G2_13.8 (11116) #1	Parameter Ta must be 4.0 times the time step or zero

SMIB Eigenvalues Example



- After AutoCorrection, there are no more errors
- Some warnings and informational messages are still present
- Many of the warnings indicate that certain generators had no machine model, so they are being treated as a negative load

Errors and Warnings after AutoCorrection

Element Type	General Type	Model Type	Device Status	Who Am I	Validation Message
1 Generator	Pref Controller	LCFB1	Active	CHEROK4_22.0 (70106) #C4	Type=0 which means that Kdrp will always be treated as 1.0. Kdrp=-1.000 will be ignored.
2 Generator	Pref Controller	LCFB1	Active	CHEROK3_20.0 (70105) #C3	Type=0 which means that Kdrp will always be treated as 1.0. Kdrp=-1.000 will be ignored.
3 Generator	Pref Controller	LCFB1	Active	CHOLLA4_22.0 (14903) #1	Type=0 which means that Kdrp will always be treated as 1.0. Kdrp=-1.000 will be ignored.
4 Generator	Pref Controller	LCFB1	Active	FCNGEN_2_20.0 (14912) #1	Type=0 which means that Kdrp will always be treated as 1.0. Kdrp=-1.000 will be ignored.
5 Generator	Pref Controller	LCFB1	Active	CHEROK1_15.5 (70103) #C1	Type=0 which means that Kdrp will always be treated as 1.0. Kdrp=-1.000 will be ignored.
6 Generator	Machine Model	GENROU	Active	STRIKE_2_13.8 (60322) #1	Tdopp > 5*Tdopp is recommended.
7 Generator	Machine Model	GENROU	Active	STRIKE_3_13.8 (60323) #1	Tdopp > 5*Tdopp is recommended.
8 Generator	Machine Model	GENTPF	Active	CHELAN_11.0 (46803) #A1	Tdopp > 5*Tdopp is recommended.
9 Generator	Machine Model	GENTPF	Active	RI_NORTH_13.8 (46893) #B7	Tdopp > 5*Tdopp is recommended.
10 Generator	Machine Model	GENTPF	Active	RI_NORTH_13.8 (46893) #B6	Tdopp > 5*Tdopp is recommended.
11 Generator	Machine Model	GENTPF	Active	RI_SOUTH_13.8 (46895) #B9	Tdopp > 5*Tdopp is recommended.
12 Generator	Machine Model	GENTPF	Active	CUSHMN2_12.6 (46791) #1	Tdopp > 5*Tdopp is recommended.
13 Generator	Machine Model	GENTPF	Active	RI_STUB1_13.8 (46889) #B1	Tdopp > 5*Tdopp is recommended.
14 Generator	Machine Model	GENTPF	Active	CHELAN_11.0 (46803) #A2	Tdopp > 5*Tdopp is recommended.
15 Generator	Machine Model	GENTPF	Active	RI_SOUTH_13.8 (46895) #B8	Tdopp > 5*Tdopp is recommended.
16 Generator	Machine Model	GENTPF	Active	RI_SOUTH_13.8 (46895) #B4	Tdopp > 5*Tdopp is recommended.
17 Load				SOMLFRD2_25.0 (67379) #1	Load is only 0.0000 MW. MOTORW below 0.50 MW are ignored and default model used.
18 Load				COMMERCE_12.5 (66637) #1	Load is only 0.0000 MW. MOTORW below 0.50 MW are ignored and default model used.
19 Load				MILFORD_12.5 (67247) #1	Load is only 0.0000 MW. MOTORW below 0.50 MW are ignored and default model used.
20 Load				RODEO_120.0 (64281) #1	Load is only 0.0000 MW. MOTORW below 0.50 MW are ignored and default model used.
21 Load				CONDA_46.0 (67098) #1	Load is only 0.0000 MW. MOTORW below 0.50 MW are ignored and default model used.
22 Load				TOQUERVL_34.5 (66558) #99	Load is only 0.0000 MW. MOTORW below 0.50 MW are ignored and default model used.
23 Load				SOMLFRD1_12.5 (67378) #1	Load is only 0.0000 MW. MOTORW below 0.50 MW are ignored and default model used.
24 Load				ROASTER_120.0 (64282) #1	Load is only 0.0000 MW. MOTORW below 0.50 MW are ignored and default model used.

SMIB Eigenvalues Example



- Open the case **WestExample.pwb**
- This case provides an example of using SMIB eigenvalues to identify input parameters which cause instability
- Open the SMIB Eigenvalues page on the Transient Stability Analysis dialog
- Click “Run SMIB Eigen Analysis”
- Different fields available- Number of Eigenvalues, Number of Zero Eigenvalues, Max Eigenvalue, Min Eigenvalue, all eigenvalues
- You can click on the Max Eigenvalue Column to sort by Max Eigenvalue and view the largest eigenvalues; positive eigenvalues are present

Positive Maximum Eigenvalues



Sort by Max Eigenvalue

SMIB Eigenvalues

Run SMIB Eigen Analysis Re-Initialize Eigenvalue Analysis Last Run: 5/10/2019 11:31:53 AM

Number of Bus	Name of Bus	ID	MVA Base	Area Name of Gen	Machine	Exciter	Governor	Stabilizer	Calculate	Number of Eigenvalues	Number of Zero Eigenvalues	Max Eigenvalue	Min Eigenvalue
1	21081 NINDGT#1	1	71.2	IMPERIALCA	GENROU	ESAC7B		PSS2A	YES	22	0	7.2083	-71.7206
2	21083 NINDGT#2	1	71.2	IMPERIALCA	GENROU	ESAC7B		PSS2A	YES	22	0	7.2083	-71.7206
3	57236 MUSKEG4	1	104.7	ALBERTA	GENROU	ESAC7B	GGOV1	PSS2A	YES	31	1	6.2374	-49.3014
4	57836 MUSKEG6	2	104.7	ALBERTA	GENROU	ESAC7B	GGOV1	PSS2A	YES	31	1	6.2372	-49.3023
5	51444 BKL 151	1	12.0	B.C.HYDRO	GENROU				YES	6	0	1.2344	-45.0356
6	58290 BALZ 1&2	3	33.0	ALBERTA	GENSAL	EXAC8B	IEEEG1	PSS2A	YES	23	0	0.7590	-80.2470
7	57273 FIREBAG7	G7	103.2	ALBERTA	GENROU	ESAC7B	GGOV1	PSS2A	YES	31	1	0.4662	-49.2391
8	32171 HIGHWIND3	1	44.0	PG AND E	GENWRI	EXWTG1			YES	6	0	0.3338	-25.8852
9	46439 ROSS 42	2	100.0	NORTHWEST	GENSAL		PIDGOV	PSS2A	YES	23	0	0.1985	-33.0781
10	21062 ROCKWOD1	1	37.0	IMPERIALCA	GENROU	REXS	GGOV1		YES	17	2	0.0669	-40.1002
11	50307 JHT 13G1	1	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0541	-44.7875
12	50308 JHT 13G2	2	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0527	-41.8892
13	50310 JHT 13G4	4	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0372	-52.6239
14	58392 ALPAC2	1	71.2	ALBERTA	GENROU	IEEET1	GGOV1	WSCCST	YES	21	1	0.0362	-32.2519
15	58392 ALPAC2	2	71.2	ALBERTA	GENROU	IEEET1	GGOV1	WSCCST	YES	21	1	0.0362	-32.2519
16	50311 JHT 13G5	5	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0354	-46.0763
17	51499 HAC 4G1	1	3.8	B.C.HYDRO	GENROU				YES	6	0	0.0328	-46.0796
18	43557 SULIVAN	1	22.0	NORTHWEST	GENTPF				YES	6	0	0.0256	-64.6841
19	50309 JHT 13G3	3	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0250	-39.8359
20	50513 PCN 13G1	1	184.0	B.C.HYDRO	GENSAL	EXST1_GE	PIDGOV	PSS2A	YES	25	0	0.0119	-98.3553
21	51214 SSH 4G1	1	5.5	B.C.HYDRO	GENROU				YES	6	0	0.0069	-44.5018
22	50515 PCN 13G3	3	184.0	B.C.HYDRO	GENSAL	EXST1_GE	PIDGOV	PSS2A	YES	24	0	0.0059	-60.3494
23	51213 M3C 4G1	1	5.0	B.C.HYDRO	GENROU				YES	6	0	0.0053	-44.7986
24	51307 HVC 4G1	2	3.6	B.C.HYDRO	GENROU				YES	6	0	0.0047	-44.3283
25	51307 HVC 4G1	1	3.6	B.C.HYDRO	GENROU				YES	6	0	0.0047	-44.3283
26	52143 COR-G3	3	15.0	FORTISBC	GENSAL	EXDC4	GPWSCC		YES	14	0	0.0029	-78.7623
27	24815 GARNET	QF	162.0	SOCALIF	GENROU		GGOV1	PSS2A	YES	26	1	0.0004	-50.7027
28	70714 PTZLOGN4	W4	185.0	PSCOLORADO	GEWTG	EXWTGE		WNDTGE	YES	22	5	0.0000	-30.7208
29	27119 WTGGE	GE	65.0	LADWP	GEWTG	EXWTGE		WNDTGE	YES	25	5	0.0000	-30.6982
30	70710 PTZLOGN1	W1	185.0	PSCOLORADO	GEWTG	EXWTGE		WNDTGE	YES	22	5	0.0000	-30.7260

Positive eigenvalues are present

Extremely Large Negative Minimum Eigenvalues



SMIB Eigenvalues

Run SMIB Eigen Analysis Re-Initialize Eigenvalue Analysis Last Run: 5/10/2019 11:31:53 AM

Number of Bus	Name of Bus	ID	MVA Base	Area Name of Gen	Machine	Exciter	Governor	Stabilizer	Calculate	Number of Eigenvalues	Number of Zero Eigenvalues	Max Eigenvalue	Min Eigenvalue
1	42711 ELECTRON	2	6.0	NORTHWEST	GENSAL	EXST1_GE			YES	7	0	-1.484	-2601.8113
2	42711 ELECTRON	3	6.0	NORTHWEST	GENSAL	EXST1_GE			YES	7	0	-1.693	-2101.6555
3	42711 ELECTRON	1	6.0	NORTHWEST	GENSAL	EXST1_GE			YES	7	0	-1.731	-2101.6355
4	42711 ELECTRON	4	9.4	NORTHWEST	GENSAL	EXST1_GE			YES	7	0	-1.007	-1477.0999
5	36405 MOSSLND6	H	442.8	PG AND E	GENCC	EXST1_GE	IEEEG1	IEEEST	YES	18	4	-0.100	-1296.9680
6	36406 MOSSLND7	H	442.8	PG AND E	GENCC	EXST1_GE	IEEEG1	IEEEST	YES	18	4	-0.100	-1296.9679
7	54414 RAV RES9	1	22.8	ALBERTA	GENSAL	EXST1_GE	GPWSCC		YES	14	0	-0.007	-1042.9832
8	54424 KEEP#2GN	2	448.0	ALBERTA	GENROU	EXST1_GE	IEEEG1	IEEEST	YES	20	4	-0.491	-982.4062
9	54407 CHIN CH9	1	13.8	ALBERTA	GENSAL	EXST1_GE	GPWSCC		YES	14	0	-0.007	-918.4131
10	54422 KEEP#1GN	1	448.0	ALBERTA	GENROU	EXST1_GE	IEEEG1	IEEEST	YES	20	4	-0.494	-900.4973
11	36405 MOSSLND6	L	377.2	PG AND E	GENCC	EXST1_GE		IEEEST	YES	15	4	-0.100	-899.4741
12	36406 MOSSLND7	L	377.2	PG AND E	GENCC	EXST1_GE		IEEEST	YES	15	4	-0.100	-899.4740
13	54268 DOME EA9	1	100.0	ALBERTA	GENSAL	EXST1_GE			YES	9	0	-0.826	-799.7054
14	54268 DOME EA9	E1	100.0	ALBERTA	GENSAL	EXST1_GE			YES	9	0	-0.866	-771.6896
15	54288 DOME EC9	1	100.0	ALBERTA	GENSAL	EXST1_GE			YES	9	0	-0.858	-771.6896
16	54287 DOME EB9	1	100.0	ALBERTA	GENSAL	EXST1_GE			YES	9	0	-0.795	-771.6892
17	54289 DOME EM9	2	100.0	ALBERTA	GENSAL	EXST1_GE			YES	9	0	-0.756	-771.6772
18	54289 DOME EM9	1	100.0	ALBERTA	GENSAL	EXST1_GE			YES	9	0	-0.820	-771.6747
19	54287 DOME EB9	E2	22.4	ALBERTA	GENSAL	EXST1_GE			YES	9	0	-0.789	-771.6708
20	24309 B CRK2-2	4	17.5	SOCALIF	GENSAL	EXST1_GE	HYGOV4		YES	12	0	-0.590	-767.4624
21	43369 OAKGROVE	1	30.0	NORTHWEST	GENSAL	EXST1_GE	HYGOV		YES	12	0	-0.003	-743.3486
22	43369 OAKGROVE	2	30.0	NORTHWEST	GENSAL	EXST1_GE	HYGOV		YES	12	0	-0.003	-743.3486
23	31906 COLEMAN	1	14.0	PG AND E	GENSAL	EXST1_GE			YES	7	0	-1.235	-724.8263
24	65680 GOSHEN	1	75.0	PACE	GENSAL	EXST1_GE			YES	7	0	-0.366	-634.0287
25	65150 BENLOMND	1	75.0	PACE	GENSAL	EXST1_GE			YES	7	0	-0.615	-633.9402
26	26007 CASTA4G	4	250.0	LADWP	GENSAL	EXST1_GE	PIDGOV	IEEEST	YES	21	4	-0.018	-600.9643
27	45023 BOYLE 1	1	42.1	NORTHWEST	GENSAL	EXST1_GE	IEEEG3_GE		YES	12	0	-0.015	-551.6839
28	46789 CUSHMNT1	1	28.0	NORTHWEST	GENTPF	EXST1_GE	GPWSCC	WSCCST	YES	18	0	-0.033	-515.0048
29	25603 DVLICN3G	3	82.5	SOCALIF	GENSAL	EXST1_GE	HYGOV	IEEEST	YES	20	4	-0.005	-504.9594
30	25604 DVLICN4G	4	82.5	SOCALIF	GENSAL	EXST1_GE	HYGOV	IEEEST	YES	20	4	-0.005	-504.9525

Sort by Min Eigenvalue

SMIB Eigenvalues Dialog



- Sort by Max Eigenvalue
- Look for Bus 57236
- Right-click, then "Show SMIB Dialog"
- Three tabs are available- General Info, A Matrix, Eigenvalues

Click to display the SMIB dialog

SMIB Eigenvalues

Run SMIB Eigen Analysis Re-Initialize Eigenvalue Analysis Last Run: 5/10/2019 12:17:01 PM

Number of Bus	Name of Bus	ID	MVA Base	Area Name of Gen	Machine	Exciter	Governor	Stabilizer	Calculate	Number of Eigenvalues	Number of Zero Eigenvalues	Max Eigenvalue
1	21081 NINDGT#1	1	71.2	IMPERIALCA	GENROU	ESAC7B		PSS2A	YES	22	0	7.2083
2	21083 NINDGT#2	1	71.2	IMPERIALCA	GENROU	ESAC7B		PSS2A	YES	22	0	7.2083
3	57236 MUSKEG6	1	104.7	ALBERTA	GENROU	ESAC7B	GGOV1	PSS2A	YES	31	1	6.2374
4	57836 MUSKEG6	1			GENROU	ESAC7B	GGOV1	PSS2A	YES	31	1	6.2374
5	51444 BIL 151				GENROU	REXS			YES	6	0	1.2344
6	58290 BALZ 1&2				GENSAL	EXAC8B	IEEEG1	PSS2A	YES	23	0	0.7590
7	57273 FIREBAG7				GENROU	ESAC7B	GGOV1	PSS2A	YES	31	1	0.4662
8	32171 HIGHWIND				GENWRI	EXWTG1			YES	6	0	0.3338
9	46439 ROSS 42				GENSAL	REXS	PIDGOV	PSS2A	YES	23	0	0.1985
10	21062 ROCKWOC				GENROU	REXS	GGOV1		YES	17	2	0.0669
11	50307 JHT 13G1				GENSAL	EXDC4	HIGOV		YES	11	0	0.0541
12	50308 JHT 13G2				GENSAL	EXDC4	HIGOV		YES	11	0	0.0527
13	50310 JHT 13G4				GENSAL	EXDC4	HIGOV		YES	11	0	0.0372
14	58392 ALPAC2				GENROU	IEEET1	GGOV1	WSCCST	YES	21	1	0.0362
15	58392 ALPAC2				GENROU	IEEET1	GGOV1	WSCCST	YES	21	1	0.0362
16	50311 JHT 13G5				GENSAL	EXDC4	HIGOV		YES	11	0	0.0354
17	51499 HAC 4G1				GENROU				YES	6	0	0.0328
18	43557 SULIVAN				GENTPF				YES	6	0	0.0256
19	50309 JHT 13G3				GENSAL	EXDC4	HIGOV		YES	11	0	0.0250
20	50513 PCN 13G1				GENSAL	EXST1_GE	PIDGOV	PSS2A	YES	25	0	0.0119
21	51214 SSH 4G1				GENROU				YES	6	0	0.0069
22	50515 PCN 13G3				GENSAL	EXST1_GE	PIDGOV	PSS2A	YES	24	0	0.0059
23	51213 MSC 4G1				GENROU				YES	6	0	0.0053
24	51307 HVC 4G1				GENROU				YES	6	0	0.0047
25	51307 HVC 4G1				GENROU				YES	6	0	0.0047

SMIB Eigenvalues Dialog



- General Info Tab
 - Generator MVA Base
 - Infinite bus magnitude and angle, terminal voltage and current magnitude and angle
 - Network impedance on System MVA base and Generator MVA Base

SMIB dialog-
General Info tab

SMIB Eigenvalues Dialog



- A Matrix Tab
 - Sensitivity of each SMIB dynamic state equation to each state of the generator
 - Values in Eigenvalues tab are evaluated from this matrix
 - Can right click and save out SMIB info
 - CSV
 - Excel
 - Aux file

Row Name	Machine Angle	Machine Speed w	Machine Eq	Machine PsiDp	Machine PsiQpp	Machine Edp
1 Machine Angle	0.0000	376.9911	0.0000	0.0000	0.0000	0.0000
2 Machine Speed w	-0.1286	-0.0597	-0.0337	-0.0990	0.0427	0.0054
3 Machine Eq	-0.1010	0.1586	-1.7471	1.4215	-0.0692	-0.0087
4 Machine PsiDp	-5.6784	-4.1858	28.5208	-34.3420	-0.8085	-0.0101
5 Machine PsiQpp	3.5240	-6.4391	0.0363	0.1066	-28.9846	19.8061
6 Machine Edp	0.2292	-0.4189	-0.2796	-0.8208	9.0511	-13.1429
7 Exciter VE	-22.2900	-4.1733	-357.2854	297.0940	-6.2901	-0.7927
8 Exciter Sensed Vt	-4.6256	33.2879	5.1048	14.9852	23.7605	2.9942
9 Exciter Kir	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
10 Exciter VA	-2.4894	-1.8350	-43.0789	35.0506	-1.7072	-0.2151
11 Governor PElec Measured	3.0705	1.4259	0.8052	2.3638	-1.0190	-0.1284
12 Governor Governor Differ	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
13 Governor Governor Integra	0.0000	-3.5000	0.0000	0.0000	0.0000	0.0000
14 Governor Turbine Actuator	0.0000	-21.2500	0.0000	0.0000	0.0000	0.0000
15 Governor Turbine LL	0.0000	4.9412	0.0000	0.0000	0.0000	0.0000
16 Governor Turbine Load Lim	0.0000	0.1757	0.0000	0.0000	0.0000	0.0000
17 Governor Turbine Load Inte	0.0000	-1.4238	0.0000	0.0000	0.0000	0.0000
18 Governor Supervisory Load	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
19 Governor Accel Control	0.0000	-100.0000	0.0000	0.0000	0.0000	0.0000
20 Governor Temp Detection L	0.0000	0.0264	0.0000	0.0000	0.0000	0.0000
21 Stabilizer WOTW1	0.0000	-0.5000	0.0000	0.0000	0.0000	0.0000
22 Stabilizer WOTW2	0.0000	-0.5000	0.0000	0.0000	0.0000	0.0000
23 Stabilizer WOTW3	-0.7676	-0.3565	-0.2013	-0.5909	0.2548	0.0321
24 Stabilizer Transducer2	0.1305	0.0606	0.0342	0.1005	-0.0433	-0.0055
25 Stabilizer LL1	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
26 Stabilizer LL2	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
27 Stabilizer RampFilter1	0.0000	99999.9925	0.0000	0.0000	0.0000	0.0000
28 Stabilizer RampFilter2	0.0000	49999.9963	0.0000	0.0000	0.0000	0.0000
29 Stabilizer RampFilter3	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
30 Stabilizer RampFilter4	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

SMIB Eigenvalues Dialog



- Eigenvalues
 - The SMIB eigenvalues
 - Each row corresponds to an eigenvalue
 - Columns contain real part, imaginary part, damping ratio, damping frequency, participation factors, and more
 - Participation factors show how system states contribute to (“participate in”) a particular eigenvalue

Generator Information (on Generator MVA Base)

General Info | A Matrix | **Eigenvalues** | SMIB dialog- Eigenvalues tab | Participation factors

	Real Part	Imag Part	Magnitude	Damping Ratio	Damped Freq (Hz)	Damped Period (Sec)	Undamped Freq (Hz)	Machine Angle	Machine Speed w
1	-46.5973	13.9377	48.6371	0.9581	2.2183	0.4508	7.7408	0.0050	0.0037
2	-46.5973	-13.9377	48.6371	0.9581	-2.2183	-0.4508	7.7408	0.0050	0.0037
3	-49.3014	0.0000	49.3014	1.0000	0.0000		7.8466	0.0003	0.0002
4	-36.3668	0.0000	36.3668	1.0000	0.0000		5.7879	0.0000	0.0000
5	-9.5054	20.0078	22.1510	0.4291	3.1843	0.3140	3.5254	0.0464	0.1814
6	-9.5054	-20.0078	22.1510	0.4291	-3.1843	-0.3140	3.5254	0.0464	0.1814
7	-17.5563	0.0000	17.5563	1.0000	0.0000		2.7942	0.0007	0.3206
8	-15.3896	0.0000	15.3896	1.0000	0.0000		2.4493	0.0002	0.0924
9	6.2734	0.0000	6.2734	-1.0000	0.0000		0.9984	0.4601	0.1285
10	-11.8393	5.4867	13.0488	0.9073	0.8732	1.1452	2.0768	0.0001	0.2960
11	-11.8393	-5.4867	13.0488	0.9073	-0.8732	-1.1452	2.0768	0.0001	0.2960
12	-10.0000	0.0000	10.0000	1.0000	0.0000		1.5915	0.0000	0.0000
13	-7.7551	5.1768	9.3242	0.8317	0.8239	1.2137	1.4840	0.0001	0.4106
14	-7.7551	-5.1768	9.3242	0.8317	-0.8239	-1.2137	1.4840	0.0001	0.4106
15	-5.7564	0.0000	5.7564	1.0000	0.0000		0.9162	0.0003	0.0001
16	2.0042	0.0000	2.0042	-1.0000	0.0000		0.3190	0.8556	0.0821
17	-1.9735	2.9366	3.5381	0.5578	0.4674	2.1396	0.5631	0.0127	0.5077

SMIB Eigenvalues Dialog



Pole locations $s = -\sigma \pm j\omega_d$

$$\sigma = \zeta \omega_n$$

$$\omega_d = \omega_n \sqrt{1 - \zeta^2}$$

Damping ratio ζ

Damped natural frequency ω_d

Undamped natural frequency ω_n

Decay rate of exponential envelope σ




Diagram labels: $-\sigma$, ω_d , ω_n , ζ , $\frac{\omega_d}{2\pi}$, $\frac{2\pi}{\omega_d}$, $\frac{\sigma}{\omega_n}$, $\frac{2\pi}{\omega_d}$


	Real Part	Imag Part	Magnitude	Damping Ratio	Damped Freq (Hz)	Damped Period (Sec)	Undamped Freq (Hz)
1	-46.5973	13.9377	48.6371	0.9581	2.2183	0.4508	7.7408
2	-46.5973	-13.9377	48.6371	0.9581	-2.2183	-0.4508	7.7408
3	-49.3014	0.0000	49.3014	1.0000	0.0000		7.8466
4	-36.3668	0.0000	36.3668	1.0000	0.0000		5.7879

G. F. Franklin, J. D. Powell, A. Emami-Naeini, *Feedback Control of Dynamic Systems*, 5th edition, Prentice Hall, 2006.

SMIB Eigenvalues Example



- One problem is that several **PIDGOV** models have parameters R_{perm} (droop) which are negative
- This creates a positive feedback instead of a negative feedback and eventually causes the system to become unstable
- Open the Model Explorer to the Governors page and view the data for the **PIDGOV** models
- There are two active **PIDGOV** models with negative R_{perm} , located at buses 50515 and 50513



SMIB Eigenvalues Example



- Going back to the SMIB page, we can confirm that these generators are associated with positive eigenvalues

Number of Bus	Name of Bus	ID	MVA Base	Area Name of Gen	Machine	Exciter	Governor	Stabilizer	Calculate	Number of Eigenvalues	Number of Zero Eigenvalues	Max Eigenvalue
1	21081 NLNDGT#1	1	71.2	IMPERIALCA	GENROU	ESAC7B		PSS2A	YES	22	0	7.2083
2	21083 NLNDGT#2	1	71.2	IMPERIALCA	GENROU	ESAC7B		PSS2A	YES	22	0	7.2083
3	57236 MUSKEG4	1	104.7	ALBERTA	GENROU	ESAC7B	GGOV1	PSS2A	YES	31	1	6.2734
4	57836 MUSKEG6	2	104.7	ALBERTA	GENROU	ESAC7B	GGOV1	PSS2A	YES	31	1	6.2372
5	51444 BKL 1S1	1	12.0	B.C.HYDRO	GENROU				YES	6	0	1.2344
6	58290 BALZ 1&2	3	33.0	ALBERTA	GENSAL	EXAC8B	IEEEG1	PSS2A	YES	23	0	0.7590
7	57273 FIREBAG7	G7	103.2	ALBERTA	GENROU	ESAC7B	GGOV1	PSS2A	YES	31	1	0.4662
8	32171 HIGHWIND3	1	44.0	PG AND E	GENWRI	EXWTG1			YES	6	0	0.3338
9	46439 ROSS 42	2	100.0	NORTHWEST	GENSAL		PIDGOV	PSS2A	YES	23	0	0.1985
10	21062 ROCKWOD1	1	37.0	IMPERIALCA	GENROU	REXS	GGOV1		YES	17	2	0.0669
11	50307 JHT 13G1	1	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0541
12	50308 JHT 13G2	2	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0527
13	50310 JHT 13G4	4	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0372
14	58392 ALPAC2	1	71.2	ALBERTA	GENROU	IEEET1	GGOV1	WSCCST	YES	21	1	0.0362
15	58392 ALPAC2	2	71.2	ALBERTA	GENROU	IEEET1	GGOV1	WSCCST	YES	21	1	0.0362
16	50311 JHT 13G5	5	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0354
17	51499 HAC 4G1	1	3.8	B.C.HYDRO	GENROU				YES	6	0	0.0328
18	43557 SULIVAN	1	22.0	NORTHWEST	GENTPF				YES	6	0	0.0256
19	50309 JHT 13G3	3	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES	11	0	0.0250
20	50513 PCN 13G1	1	184.0	B.C.HYDRO	GENSAL	EXST1_GE	PIDGOV	PSS2A	YES	25	0	0.0119
21	51213 M3C 4G1	1	5.0	B.C.HYDRO	GENROU				YES	6	0	0.0069
22	50515 PCN 13G3	3	184.0	B.C.HYDRO	GENSAL	EXST1_GE	PIDGOV	PSS2A	YES	24	0	0.0059
23	51213 M3C 4G1	1	5.0	B.C.HYDRO	GENROU				YES	6	0	0.0053
24	51307 HVC 4G1	2	3.6	B.C.HYDRO	GENROU				YES	6	0	0.0047
25	51307 HVC 4G1	1	3.6	B.C.HYDRO	GENROU				YES	6	0	0.0047

Two PIDGOV models with negative Rperm

SMIB Two-Bus Equivalent



- Let's save out the two-bus equivalent for the bus 50513
- Save it as **Gen_50513_1.pwb** (this should be the default name that appears in the save dialog) Save two-bus equivalent for this bus

Number of Bus	Name of Bus	ID	MVA Base	Area Name of Gen	Machine	Exciter	Governor	Stabilizer	Ca
1	21081 NLDGT#1	1	71.2	IMPERIALCA	GENROU	ESACTB		PSS2A	YES
2	21083 NLDGT#2	1	71.2	IMPERIALCA	GENROU	ESACTB		PSS2A	YES
3	57236 MUSKEG4	1	104.7	ALBERTA	GENROU	ESACTB	GGOV1	PSS2A	YES
4	57836 MUSKEG6	2	104.7	ALBERTA	GENROU	ESACTB	GGOV1	PSS2A	YES
5	51444 BKL 1S1	1	12.0	B.C.HYDRO	GENROU				YES
6	58290 BALZ 1&2	3	33.0	ALBERTA	GENSAL	EXAC8B	IEEEG1	PSS2A	YES
7	57273 FIREBAG7	G7	103.2	ALBERTA	GENROU	ESACTB	GGOV1	PSS2A	YES
8	32171 HIGHWIND3	1	44.0	P AND E	GENWRI	EXWTG1			YES
9	46439 ROSS 42	2	100.0	NORTHWEST	GENSAL		PIDGOV	PSS2A	YES
10	21062 ROCKWOOD1	1	37.0	IMPERIALCA	GENROU	REXS	GGOV1		YES
11	50307 JHT 13G1	1	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES
12	50308 JHT 13G2	2	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES
13	50310 JHT 13G4	4	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES
14	58392 ALPAC2	1	71.2	ALBERTA	GENROU	IEEET1	GGOV1	WSSCST	YES
15	58392 ALPAC2	2	71.2	ALBERTA	GENROU	IEEET1	GGOV1	WSSCST	YES
16	50311 JHT 13G5	5	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES
17	51499 HAC 4G1	1	3.8	B.C.HYDRO	GENROU				YES
18	43557 SULIVAN	1	22.0	NORTHWEST	GENTPF				YES
19	50309 JHT 13G3	3	25.0	B.C.HYDRO	GENSAL	EXDC4	HYGOV		YES
20	50513 PCN 13G1	1	184.0	B.C.HYDRO	GENSAL	EXST1_GE	PIDGOV	PSS2A	YES
21	51214 SMR 4G1	1	5.0	B.C.HYDRO	GENROU				YES
22	50515 PCN 13G3	3	184.0	B.C.HYDRO	GENSAL	EXST1_GE	PIDGOV	PSS2A	YES
23	51213 M3C 4G1	1	5.0	B.C.HYDRO	GENROU				YES

SMIB Two-Bus Equivalent



- Now open **Gen_50513_1.pwb**, the two-bus equivalent
- Open the Model Explorer to the bus records or the Models in Use to see some of what is in this case


Number	Name	Area Name	Nom KV	PU Volt	Volt (kV)	Angle (Deg)	Load MW	Load Mvar	Gen MW
1	Infinite Bus	1	13.80	1.00694	13.896	0.00			0.00
2	50513 PCN 13G1	1	13.80	0.98988	13.660	8.25			174.80

Model Class	Object Type	Active and Online Count	Active Count	Inactive Count	Fully Supported
1 Machine Model	GENCLS	1	1	0	YES
2 Machine Model	GENSAL	1	1	0	YES
3 Exciter	EXST1_GE	1	1	0	YES
4 Governor	PIDGOV	1	1	0	YES
5 Stabilizer	PSS2A	1	1	0	YES

SMIB Two-Bus Equivalent



- Open the Transient Stability Analysis dialog
- Go to the Plots tab and quickly create a plot definition for the Rotor Angle of bus 50513
- Do not insert any events; keep the End Time set to the default 10 seconds
- Click “Run Transient Stability”
- Now change the simulation time to 2000 seconds and run it again



The model is unstable

SMIB Participation Factors



- Open the SMIB Eigenvalue Information dialog
- Open the Eigenvalues tab and sort by “Real Part” so that the positive eigenvalue is at the top
- Scroll over and look at the participation factors for this eigenvalue
- These tell how the states map to a particular eigenvalue

Generator SMIB Eigenvalue Information

Bus Number: 50513, Bus Name: PCN 13G1, ID: 1, Area Name: 50 (50)

Generator Information (on Generator MVA Base)

	Exciter VF	Governor Mechanical Output	Governor Measured Delta P	Governor Ki	Governor Reg1	Governor Derivative
1	0.0000	0.0263	0.0000	0.9996	0.0062	0.0000
2	0.0000	0.8319	0.0067	0.1754	0.3031	0.0000
3	0.0000	0.4189	0.0116	0.0449	0.5230	0.0000
4	0.0000	0.4189	0.0116	0.0449	0.5230	0.0000
5	0.0000	0.0963	0.0017	0.0088	0.2651	0.0000
6	0.0000	0.0449	0.0077	0.0047	0.1256	0.0000
7	0.0000	0.0003	0.0000	0.0009	0.0001	0.0000
8	0.0000	0.0000	0.0000	0.0007	0.0000	0.0000
9	0.0000	0.0000	0.0000	0.0002	0.0000	0.0000
10	0.0000	0.0018	0.0007	0.0002	0.0061	0.0000
11	0.0000	0.0018	0.0007	0.0002	0.0061	0.0000
12	0.0000	0.0004	0.0002	0.0001	0.0015	0.0000
13	0.0000	0.0004	0.0002	0.0001	0.0015	0.0000
14	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
15	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
16	0.0000	0.0000	0.0000	0.0000	0.0001	0.0000

The state “Governor PI” makes a large contribution (0.9996) to the positive eigenvalue, while other contributions are zero or close to zero

SMIB Eigenvalues Example



- Re-enable the ESAC7B exciter; Re-Initialize and re-run the analysis

Disabling GGOV1 and PSS2A makes the generator's SMIB Eigenvalues negative

	Number of B ▼	Name of Bus	ID	Area Name of Gen	Machine	Exciter	Governor	Stabilizer	Calculated	Number of Eigenvalues	Number of Zero Eigenvalues	Max Eigenvalue	Min Eigenvalue
697	57259	HORUP8	1B	ALBERTA					NO	0	0		
698	57249	LNLKCG2	G1	ALBERTA	GENROU REXS		GGOV1	PSS2A	YES	31	2	0.0537	-179.0248
699	57236	MUSKEG4	1	ALBERTA	GENROU ESAC7B		GGOV1	PSS2A	YES	10	0	-0.3852	-47.9088
700	57233	SYNC_UE4	11	ALBERTA	GENROU EXAC1		IEEEG1	PSS2A	YES	24	0	-0.0999	-61.7009
701	57210	SYNC_G49	21	ALBERTA	GENSAL				NO	0	0		

- This generator still has only negative eigenvalues, so we know its positive eigenvalue was associated with its governor or stabilizer

Disabling only PSS2A still makes the generator's SMIB Eigenvalues negative

	Number of B ▼	Name of Bus	ID	Area Name of Gen	Machine	Exciter	Governor	Stabilizer	Calculated	Number of Eigenvalues	Number of Zero Eigenvalues	Max Eigenvalue	Min Eigenvalue
697	57259	HORUP8	1B	ALBERTA					NO	0	0		
698	57249	LNLKCG2	G1	ALBERTA	GENROU REXS		GGOV1	PSS2A	YES	31	2	0.0537	-179.0248
699	57236	MUSKEG4	1	ALBERTA	GENROU ESAC7B		GGOV1	PSS2A	YES	20	1	-0.2932	-47.9088
700	57233	SYNC_UE4	11	ALBERTA	GENROU EXAC1		IEEEG1	PSS2A	YES	24	0	-0.0999	-61.7009
701	57210	SYNC_G49	21	ALBERTA	GENSAL				NO	0	0		

- If we disable only the stabilizer, we again find that this generator has only negative eigenvalues
- This indicates that we should more carefully consider the PSS2A model and its parameters

SMIB Eigenvalues Example



- However, now disable only the exciter ESAC7B and re-enable the other models
- Leave both GGOV1 and PSS2A active and Re-Initialize and run the analysis again
- Interestingly, the Max Eigenvalue for bus 57236 now changes to zero

Disabling ESAC7B makes the generator's SMIB Max Eigenvalue is negative BUT...

	Number of B ▼	Name of Bus	ID	Area Name of Gen	Machine	Exciter	Governor	Stabilizer	Calculated	Number of Eigenvalues	Number of Zero Eigenvalues	Max Eigenvalue	Min Eigenvalue
697	57259	HORUP8	1B	ALBERTA					NO	0	0		
698	57249	LNLKCG2	G1	ALBERTA	GENROU REXS		GGOV1	PSS2A	YES	31	2	0.0537	-179.0248
699	57236	MUSKEG4	1	ALBERTA	GENROU ESAC7B		GGOV1	PSS2A	YES	27	1	-0.1134	-36.5528
700	57233	SYNC_UE4	11	ALBERTA	GENROU EXAC1		IEEEG1	PSS2A	YES	24	0	-0.0999	-61.7009
701	57210	SYNC_G49	21	ALBERTA	GENSAL				NO	0	0		

- Open the SMIB Dialog
- You will see that there is a negative eigenvalues
- These zero eigenvalues are caused by the ignored states- an ignored state will have a participation factor of one for one of the zero eigenvalues
- This is true for a lot (but not all) of the zero eigenvalues in the case

General Info		A Matrix	Eigenvalues
Real Part	Imag Part		
14	0.0000		0.0000
21	-0.1134		0.0000

SMIB Eigenvalues Example



- Let's look at the participation factors for the maximum eigenvalue of Bus 57236
- Re-enable all of the models for Bus 57236 if you disabled them
- Click "Re-Initialize" and "Run SMIB Eigen Analysis"
- Then, right-click and "Show SMIB Dialog" for Bus 57236
- Open the Eigenvalues tab and sort by "Real Part"
- There are actually two positive eigenvalues for this generator which are complex conjugates
- The state "Stabilizer Transducer 2" has a relatively large participation factor, but it is not the largest (scroll over and look at the other states, especially some of the machine states)
- In this example, the cause of the instability does not seem as obvious to identify

SMIB Eigenvalues Example



- Let's save out the 2-bus equivalent for the bus 57236
- Save it as **Gen_57236_1.pwb** (this should be the default name that appears in the save dialog) Save two-bus equivalent for this bus

SMIB Eigenvalues


Run SMIB Eigen Analysis Re-Initialize Eigenvalue Analysis Last Run: 2/10/2015 5:31:30 PM

	Number of B	Name of Bus	ID	Area Name of Gen	Machine	Exciter	Governor	Stabilizer	Calculated	Number of Eigenvalues	Number of Zero Eigenvalues	Max Eigenvalue	Min Eigenvalue
699	57236	MUSK... 57236			GEN... 57236	ESAC7B	GGOV1	PSS2A	YES	31	1	6.2734	-49.3014
700	57233	SYNC 57233				EXAC1	IEEEG1	PSS2A	YES	24	0	-0.0999	-61.7009
701	57210	SYNC 57210							NO	0	0		
702	57210	SYNC 57210							NO	0	0		
703	57210	SYNC 57210				EXST1_GE	IEEEG1	WSSCST	YES	12	0	-0.6573	-31.7789
704	57209	SYNC 57209				EXDC1	GGOV1		YES	20	0	-0.0101	-39.3860
705	57134	ELMV 57134				EXST4B	GGOV1		NO	0	0		
706	57134	ELMV 57134				EXST4B	GGOV1		NO	0	0		
707	57134	ELMV 57134				EXST4B	GGOV1		NO	0	0		
708	57134	ELMV 57134				EXST4B	GGOV1		NO	0	0		
709	57134	ELMV 57134				EXDC2_GE	GGOV1		NO	0	0		
710	57120	LOW 57120				EXAC2	GGOV1	PSS2A	NO	0	0		
711	57101	GPEF 57101				EXAC6A	IEEEG1	PSS2A	YES	24	0	-0.1714	-61.5237
712	56941	LON 56941							NO	0	0		
713	56885	SCOT 56885				EXST1_GE	GGOV1	PSS2A	YES	28	1	-0.0999	-50.0003
714	56858	SOD 56858							NO	0	0		
715	56785	SCOT 56785							NO	0	0		
716	56516	CB 56516				EXAC2	GPWSCC	PSS2A	NO	0	0		
717	56503	SUM 56503				ESAC7B	IEEEG1	PSS2A	YES	23	1	-0.0656	-37.8982
718	56443	TARR 56443							NO	0	0		

SMIB Eigenvalues Example




- Open [Gen_57236_1.pwb](#)
- It has two buses, the slack bus which is also the infinite bus, and bus 57236 with attached generator models
- Running the analysis for 500 seconds with no event does not cause numerical instability like in the earlier example
- More analysis is needed to determine what is causing the positive eigenvalues



Gen_57236_1, stabilizer states

The stabilizer is the only model with states that are not completely flat, as they should be in steady-state



Gen_57236_1, all other states